

Rapinder Kaur Kler

From: Sarah Day [REDACTED]
Sent: 25 July 2022 13:37
To: dal.kaur@hotmail.com; Licensing
Subject: Application for a Premises Licence. West Midlands Authority Response. NO REPS
Attachments: CLG_Offices_and_Shops_FIRE SAFETY GUIDE.pdf

CAUTION: STOP and THINK - This email originated from outside of the council. If it looks suspicious it probably is and you should NEVER enter your council username and password into an external link or open attachments.

OFFICIAL

LICENSING ACT 2003
NAME OF PREMISES: Sall Express
ADDRESS: 62 Walsall Road Aldridge

I refer to the application for the Grant of a Premises licence made in respect of the above premises.

Having assessed your application I am pleased to inform you that The Fire Authority will **not make representation** to the application, on the grounds of Public Safety, at this time.

What you Must do

You must carry out a Fire Risk Assessment to determine the correct fire precautions for your premises and the measures that you will need to take to keep people safe from fire.

I have attached a government guide to help in the process.

If you are in any doubt about the standards that you will need to apply, you should enlist the support of a competent, qualified Fire Risk Assessor.

From your application, I have noticed that:

- *If persons live on the upper floors of your premises, you should take one of the two following actions. NB. Egress from living accommodation should be separate from the ground floor Cafe.*
 1. *provide 1 Hour fire resisting construction to separate the commercial premises from the residential premises or,*
 2. *provide a minimum of 30 minutes fire resisting construction and a hard-wired automatic fire detection system with suitable audible sounders on the 1st floor of the premises to warn residents of a fire on the ground floor. The work should be carried out by a competent engineer.*
- An emergency lighting system appears to be required and if so, should be provided to British Standard BS5266-1.

Further advice is contained within the attached guide.

If you do not act in accordance with my advice and your legal requirements, the Fire Authority may serve an enforcement notice under the Regulatory Reform (Fire Safety) Order 2005 and may call for a review of the Premises Licence.

Should you require any further information, please do not hesitate to contact me.

Regards

WCdr Sarah Day
Fire Safety Inspecting Officer
Bilston Fire Station
Black Country North



WEST MIDLANDS FIRE SERVICE

Making the West Midlands Safer, Stronger and Healthier

**EVERYTHING.
CONNECTED**

West Midlands Fire Service

Unless expressly stated otherwise, the information contained in this e-mail is confidential and is intended only for the named recipients. You must not copy, distribute, or take any action or reliance upon it. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited. If you have received it in error please notify us immediately on 0121 380 6067 or return it to <mailto:postmaster@wmfs.net> and then destroy it.

The information contained in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

Any opinions expressed in this e-mail (including attachments) are those of the author and do not necessarily reflect the opinions of West Midlands Fire Service. Nothing in this e-mail message amounts to a contractual or other legal commitment on the part of West Midlands Fire Service unless confirmed by a communication signed on behalf of the Chief Fire Officer.

West Midlands Fire Service information is available from <http://www.wmfs.net>

This footnote also confirms that this e-mail message has been swept for the presence of computer viruses but does not guarantee that it is free from viruses and you should check all e-mail and attachments with your own anti-virus systems.

OFFICIAL