

Sayful Alom

From: Neil Aston-Baugh [REDACTED]
Sent: 23 August 2021 12:37
To: Licensing
Cc: [REDACTED]
Subject: Fw: Fire Authority removal of representation to a premises licence application .
Voluntary undertaking received Stick and Wicket
Attachments: Fire voluntary agreement signed.pdf

CAUTION: This email originated from outside of the council. If you have any doubts do not click links or open attachments. You should never be asked to enter your username and password into an external link.

OFFICIAL

LICENSING ACT 2003

NAME OF PREMISES: Stick and Wicket

ADDRESS: The Green Aldridge WS9 8HN

I refer to the representation made by the Fire Authority regarding the application for the premises licence in respect of the above premises.

The applicant through their agent, has provided a voluntary undertaking to complete works to the appropriate standards and/or restrict the use of the premises. (As attached).

The Fire Authority considers this undertaking is sufficient, to demonstrate that the Public Safety Objective (as it relates to Fire Safety), will be adequately promoted, and hereby **removes its representation to the application.**

Any voluntary undertaking that the applicant gives to the Fire Authority does not constitute Licence Conditions and should not be treated as such.

You should be aware however that failure to act in accordance with the undertaking may result in the Issue of an enforcement notice under the Regulatory Reform (Fire Safety) Order 2005 and/or a review of the premises licence.

Should you require any further information or clarification, please do not hesitate to contact me.

Regards

Neil Aston-Baugh

Fire Safety Officer -LEEPS Team
Tipton Fire Station
Alexandra Road
Tipton
West Midlands
DY4 7NZ



Fire Safety Admin Email firesafety.admin@wmfs.net



@WestMidsFire

WEST MIDLANDS FIRE SERVICE

Making the West Midlands Safer, Stronger and Healthier

OUR PLAN

2019 - 2022

From: Ian Rushton [redacted]
Sent: Monday, August 23, 2021 11:44 AM
To: Andrew Dickson [redacted] Neil Aston-Baugh [redacted]
Cc: Licensing <Licensing@walsall.gov.uk>
Subject: RE: Fire Authority representation to a premises licence application . Voluntary undertaking offer. Stick and Wicket

OFFICIAL

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Neil

Please see attached signed voluntary agreement.

Rebecca- for info.

Thanks, Ian

Ian Rushton
JL Licence and Retail
[redacted]

Sent from [Mail](#) for Windows 10

From: [Andrew Dickson](#)
Sent: 23 August 2021 11:03
To: [Neil Aston-Baugh](#)
Cc: [Ian Rushton](#)
Subject: RE: Fire Authority representation to a premises licence application . Voluntary undertaking offer. Stick and Wicket

Hi Neil,
My humble apologies for not actioning this earlier.
I have instructed Ian Rushton, our Licensing Consultant, to sign the voluntary undertaking on our behalf.

We will seek to increase the maximum numbers once we've carried out the minor modifications to the means of escape from the clubhouse as discussed with you on the day of your visit.

Kind Regards

Andrew

From: Neil Aston-Baugh [REDACTED]

Sent: 23 August 2021 08:18

To: Andrew Dickson [REDACTED]

Cc: Licensing@walsall.gov.uk

Subject: Fw: Fire Authority representation to a premises licence application . Voluntary undertaking offer. Stick and Wicket

OFFICIAL

Good Morning

I write to remind you of the Fire Authority representations and attached offer of a voluntary undertaking in respect of your application for a premises licence. I am aware that the application period expires this week and a date will be set for hearing sometime this week. I am on annual leave after tomorrow and do not return until the following Tuesday.

Please can you confirm you are happy to return the above document signed and dated, or call me to discuss any aspects that may concern you.

Many thanks.

Regards

Neil Aston-Baugh

Fire Safety Officer -LEEPS Team
Tipton Fire Station
Alexandra Road
Tipton
West Midlands
DY4 7NZ



Fire Safety Admin Email firesafety.admin@wmfs.net



@WestMidsFire

WEST MIDLANDS FIRE SERVICE

Making the West Midlands Safer, Stronger and Healthier

OUR PLAN

2019 - 2022

From: Neil Aston-Baugh

Sent: Thursday, August 12, 2021 4:42 PM

To: licensing@walsall.gov.uk <licensing@walsall.gov.uk>

Cc: [REDACTED] Andrew Dickson [REDACTED]

Subject: Fire Authority representation to a premises licence application . Voluntary undertaking offer

LICENSING ACT 2003

NAME OF PREMISES: Stick and Wicket

ADDRESS: The Green Aldridge WS9 8HN

I refer to the application for a premises licence made in respect of the above premises.

I have visited the premises and there are some fire safety issues which may affect the Licensing Objective of Public Safety.

- The means of escape (fire exits) from the premises are not suitably designed to accommodate the potential number of persons who may need to use them in the event of a fire.
- The fire alarm system may need a minor upgrade.
-

Consequently, **The Fire Authority hereby makes representation to the application.**

I can inform you that I visited the premises and have been in contact with the applicant. Following our discussion, I can offer a voluntary undertaking, to manage the use of the premises and/or complete works to the appropriate standard. A copy of the proposed undertaking is attached.

Should the applicant wish to agree, by signing, dating and returning the agreement to the Fire Authority, then The Fire Authority may be able to remove its representation.

A scan or photograph of the completed document returned by email would be acceptable.

Any voluntary undertaking that the applicant gives to the Fire Authority does not constitute licence Conditions and should not be treated as such.

You should be aware however that failure to act in accordance with the undertaking may result in the Issue of an enforcement notice under the Regulatory Reform (Fire Safety) Order 2005 and/or a review of the premises licence.

Should you require any further information or clarification, please do not hesitate to contact me.

Regards

Neil Aston-Baugh

Fire Safety Officer -LEEPS Team
Tipton Fire Station
Alexandra Road
Tipton
West Midlands
DY4 7NZ

Fire Safety Admin Email firesafety.admin@wmfs.net



@WestMidsFire

WEST MIDLANDS FIRE SERVICE

Making the West Midlands Safer, Stronger and Healthier

OUR PLAN

2019 - 2022

West Midlands Fire Service

Unless expressly stated otherwise, the information contained in this e-mail is confidential and is intended only for the named recipients. You must not copy, distribute, or take any action or reliance upon it. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited. If you have received it in error please notify us immediately on 0121 380 6067 or return it to <mailto:postmaster@wmfs.net> and then destroy it.

The information contained in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

Any opinions expressed in this e-mail (including attachments) are those of the author and do not necessarily reflect the opinions of West Midlands Fire Service. Nothing in this e-mail message amounts to a contractual or other legal commitment on the part of West Midlands Fire Service unless confirmed by a communication signed on behalf of the Chief Fire Officer.

West Midlands Fire Service information is available from <http://www.wmfs.net>

This footnote also confirms that this e-mail message has been swept for the presence of computer viruses but does not guarantee that it is free from viruses and you should check all e-mail and attachments with your own anti-virus systems.

OFFICIAL

OFFICIAL

West Midlands Fire Service

Unless expressly stated otherwise, the information contained in this e-mail is confidential and is intended only for the named recipients. You must not copy, distribute, or take any action or reliance upon it. Any unauthorised disclosure of the information contained in this e-mail is strictly prohibited. If you have received it in error please notify us immediately on 0121 380 6067 or return it to <mailto:postmaster@wmfs.net> and then destroy it.

The information contained in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000. Unless the information is legally exempt from disclosure, the confidentiality of this e-mail and your reply cannot be guaranteed.

Any opinions expressed in this e-mail (including attachments) are those of the author and do not necessarily reflect the opinions of West Midlands Fire Service. Nothing in this e-mail message amounts to a contractual or other legal commitment on the part of West Midlands Fire Service unless confirmed by a communication signed on behalf of the Chief Fire Officer.

West Midlands Fire Service information is available from <http://www.wmfs.net>

This footnote also confirms that this e-mail message has been swept for the presence of computer viruses but does not guarantee that it is free from viruses and you should check all e-mail and attachments with your own anti-virus systems.

OFFICIAL

OFFICIAL

LICENSING ACT 2003

Voluntary undertaking- Supplement to Application

NAME OF PREMISES: The Stick And Wicket

ADDRESS: . The Green Aldridge WS9 8HN

Before signing this document, you should be aware that failure to comply with this undertaking may result in a review of the premises licence and/or enforcement action under the Regulatory Reform (Fire Safety) Order 2005

PUBLIC SAFETY

- 1) The safe occupancy of the premises will be limited to 60 persons within Gordy's Bar and 60 persons within Morgan's Bar.
Suitable management procedures will be adopted to ensure that the safe occupancy is not exceeded.

The above numbers will not be increased until the means of escape have been improved and any newly proposed numbers are agreed with the fire officer.

- 2) The fire alarm system will be provided with additional means for giving warning which will comprise of either additional fire detection or an additional break glass call point for use by the coffee bar staff.

APPLICANT'S SIGNATURE.....
(or representative authorised on behalf of the Premises Licence Holder/applicant)

Date.....23-8-21

AUTHORISED OFFICER... Neil Aston-Baugh (POSITION) ... Fire Safety Inspecting Officer (Authorised on behalf of West Midlands Fire Authority)